



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

**Not Reportable as per Chain of Custody
Works #: 1156**

Project : PO#017018

14-May-2015

OCWA-Trent Valley (Quinte Mohawk School)

Attn : James Taylor

Date Rec. : 12 May 2015

LR Report: CA16171-MAY15

Box 20157, 131 St. Paul St.
Belleville, ON
K8N 5V1,

Copy: #1

Phone: 613-962-5454
Fax:pdf-ID Plant

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field Free Chlorine mg/L	Total Coliform cfu/100mL	E. Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	12-May-15	12-May-15	12-May-15
2: Analysis Start Time		---	---	14:35	14:35	14:00
3: Analysis Approval Date		--	--	14-May-15	14-May-15	14-May-15
4: Analysis Approval Time		--	--	10:28	10:28	12:21
5: MAC		--	--	0	0	---
6: 26F9D RW RW-QMS: Raw Water 26F9D RW	11-May-15 08:10	15.0	---	0	0	2
7: 6712 NR DW DW1-QMS Daycare 6712 NR/DW	11-May-15 08:15	15.0	1.31	0	0	2
8: 1F432 NR/DW DW3-QMS: Fountain Water Front Entrance 1F432 NR/DW	11-May-15 08:20	15.0	0.66	0	0	0

Method Descriptions

Parameter	Description	SGS Method Code
E. Coli	E.Coli by membrane filtration on DC media	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count by membrane filtration	ME-CA-[ENV]MIC-LAK-AN-005
Total Coliform	Total Coliform by membrane filtration using DC media	ME-CA-[ENV]MIC-LAK-AN-001


 Carrie Greenlaw
 Project Specialist
 Environmental Services, Analytical