

SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - KOL 2HO
Phone: 705-652-2000 FAX: 705-652-6365

04-June-2015

OCWA-Trent Valley (Quinte Mohawk School)

Attn : James Taylor

Date Rec. : 02 June 2015
LR Report: CA16040-JUN15

Box 20157, 131 St. Paul St.
Belleville, ON
K8N 5V1,

Copy: #1

Phone: 613-962-5454
Fax:pdf-ID Plant

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field Free Chlorine mg/L	Total Coliform cfu/100mL	E. Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	02-Jun-15	02-Jun-15	02-Jun-15
2: Analysis Start Time		---	---	13:10	13:10	12:45
3: Analysis Approval Date		--	--	04-Jun-15	04-Jun-15	04-Jun-15
4: Analysis Approval Time		--	--	11:01	11:01	11:01
5: MAC		--	--	0	0	---
6: 26F9D RW RW-QMS: Raw Water 26F9D RW	01-Jun-15 08:24	10.0	---	0	0	4
7: 6712 NR DW DW1-QMS Daycare 6712 NR/DW	01-Jun-15 08:28	10.0	1.60	0	0	0
8: 1EC6A NR DW DW2-QMS Staff Room Tap 1EC6A NR/DW	01-Jun-15 08:33	10.0	1.62	0	0	0

Method Descriptions

Parameter	Description	SGS Method Code
E. Coli	E.Coli by membrane filtration on DC media	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count by membrane filtration	ME-CA-[ENV]MIC-LAK-AN-005
Total Coliform	Total Coliform by membrane filtration using DC media	ME-CA-[ENV]MIC-LAK-AN-001


 Carrie Greenlaw
 Project Specialist
 Environmental Services, Analytical