



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Not Reportable as per Chain of Custody
Works #: 1156

Project : PO#017018

08-October-2015

OCWA-Trent Valley (Quinte Mohawk School)

Attn : James Taylor

Date Rec. : 06 October 2015

LR Report: CA16059-OCT15

Box 20157, 131 St. Paul St.
Belleville, ON
K8N 5V1,

Copy: #1

Phone: 613-962-5454
Fax:pdf-ID Plant

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field Free Chlorine mg/L	Total Coliform cfu/100mL	E. Coli Heterotrophic cfu/100mL	Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	06-Oct-15	06-Oct-15	06-Oct-15
2: Analysis Start Time		---	---	14:50	14:50	14:25
3: Analysis Approval Date		--	--	07-Oct-15	07-Oct-15	08-Oct-15
4: Analysis Approval Time		--	--	16:46	16:46	11:51
5: MAC		--	--	0	0	---
6: 26F9D RW RW-QMS: Raw Water 26F9D RW	05-Oct-15 08:44	16.0	---	29	0	17
7: 6712 NR DW DW1-QMS Daycare 6712 NR/DW	05-Oct-15 09:26	16.0	1.86	0	0	0
8: 1EC6A NR DW DW2-QMS Staff Room Tap 1EC6A NR/DW	05-Oct-15 09:35	16.0	1.81	0	0	0

Method Descriptions

Parameter	Description	SGS Method Code
E. Coli	E.Coli by membrane filtration on DC media	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count by membrane filtration	ME-CA-[ENV]MIC-LAK-AN-005
Total Coliform	Total Coliform by membrane filtration using DC media	ME-CA-[ENV]MIC-LAK-AN-001

Carrie Greenlaw
Project Specialist
Environmental Services, Analytical