



**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - KOL 2HO  
Phone: 705-652-2000 FAX: 705-652-6365

**Not Reportable as per Chain of Custody  
Works #: 1156**

**Project : PO#017018**

07-August-2015

**OCWA-Trent Valley (Quinte Mohawk School)**

Attn : James Taylor

**Date Rec. : 05 August 2015**

**LR Report: CA16098-AUG15**

Box 20157, 131 St. Paul St.  
Belleville, ON  
K8N 5V1,

**Copy: #1**

Phone: 613-962-5454  
Fax:pdf-ID Plant

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field Free Chlorine mg/L	Total Coliform cfu/100mL	E. Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	05-Aug-15	05-Aug-15	05-Aug-15
2: Analysis Start Time		---	---	13:35	13:35	13:05
3: Analysis Approval Date		--	--	06-Aug-15	06-Aug-15	07-Aug-15
4: Analysis Approval Time		--	--	13:29	13:29	11:52
5: MAC		--	--	0	0	---
6: 26F9D RW RW-QMS: Raw Water 26F9D RW	04-Aug-15 12:07	17.0	---	0	0	4
7: 6712 NR DW DW1-QMS Daycare 6712 NR/DW	04-Aug-15 12:15	17.0	0.72	0	0	0
8: 1EC6A NR DW DW2-QMS Staff Room Tap 1EC6A NR/DW	04-Aug-15 12:25	17.0	0.86	0	0	10

### Method Descriptions

Parameter	Description	SGS Method Code
E. Coli	E.Coli by membrane filtration on DC media	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count by membrane filtration	ME-CA-[ENV]MIC-LAK-AN-005
Total Coliform	Total Coliform by membrane filtration using DC media	ME-CA-[ENV]MIC-LAK-AN-001

**Carrie Greenlaw**  
Project Specialist  
Environmental Services, Analytical