



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - KOL 2HO
Phone: 705-652-2000 FAX: 705-652-6365

06-February-2015

OCWA-Trent Valley (Quinte Mohawk School)

Attn : James Taylor

Date Rec. : 04 February 2015
LR Report: CA16189-FEB15

Box 20157, 131 St. Paul St.
Belleville, ON
K8N 5V1,

Copy: #1

Phone: 613-962-5454
Fax:pdf-ID Plant

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field Free Chlorine mg/L	Total Coliform cfu/100mL	E. Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	04-Feb-15	04-Feb-15	04-Feb-15
2: Analysis Start Time		---	---	14:20	14:20	13:55
3: Analysis Approval Date		--	--	05-Feb-15	05-Feb-15	06-Feb-15
4: Analysis Approval Time		--	--	12:52	12:52	12:30
5: MAC		---	--	0	0	---
6: 26F9D RW RW-QMS: Raw Water 26F9D RW	03-Feb-15 08:30	9.0	---	49	0	8
7: 6712 NR DW DW1-QMS Daycare 6712 NR/DW	03-Feb-15 08:26	9.0	2.02	0	0	0
8: 1EC6A NR DW DW2-QMS Staff Room Tap 1EC6A NR/DW	03-Feb-15 08:20	9.0	1.85	0	0	0

Method Descriptions

	Parameter	Description	SGS Method Code
1	E. Coli	E.Coli by membrane filtration on DC media	ME-CA-[ENV]MIC-LAK-AN-001
2	Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count by membrane filtration	ME-CA-[ENV]MIC-LAK-AN-005
3	Total Coliform	Total Coliform by membrane filtration using DC media	ME-CA-[ENV]MIC-LAK-AN-001

Carrie Greenlaw
Project Specialist
Environmental Services, Analytical