



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Not Reportable as per Chain of Custody
Works #: 1156

Project : PO#017018

13-March-2015

OCWA-Trent Valley (Quinte Mohawk School)

Attn : James Taylor

Date Rec. : 11 March 2015
LR Report: CA16247-MAR15

Box 20157, 131 St. Paul St.
Belleville, ON
K8N 5V1,

Copy: #1

Phone: 613-962-5454
Fax:pdf-ID Plant

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field Free Chlorine mg/L	Total Coliform cfu/100mL	E. Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date			---	11-Mar-15	11-Mar-15	11-Mar-15
2: Analysis Start Time			---	11:10	11:10	10:40
3: Analysis Approval Date			--	12-Mar-15	12-Mar-15	13-Mar-15
4: Analysis Approval Time			--	10:32	10:32	09:42
5: MAC			--	0	0	---
6: 26F9D RW RW-QMS: Raw Water 26F9D RW	10-Mar-15 08:00	6.0	---	10	0	228
7: 6712 NR DW DW1-QMS Daycare 6712 NR/DW	10-Mar-15 08:10	6.0	1.74	0	0	0
8: 13481 NR/DW DW3-QMS: Fountain Water Boys Bathroom 13481 NR/DW	10-Mar-15 08:15	6.0	0.95	0	0	0

Method Descriptions

	Parameter	Description	SGS Method Code
1	E. Coli	E.Coli by membrane filtration on DC media	ME-CA-[ENV]MIC-LAK-AN-001
2	Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count by membrane filtration	ME-CA-[ENV]MIC-LAK-AN-005
3	Total Coliform	Total Coliform by membrane filtration using DC media	ME-CA-[ENV]MIC-LAK-AN-001

Carrie Greenlaw
Project Specialist
Environmental Services, Analytical