

SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - KOL 2H0
Phone: 705-652-2000 FAX: 705-652-6365

11-June-2015

OCWA-Trent Valley (Quinte Mohawk School)

Attn : James Taylor

Date Rec. : 09 June 2015
LR Report: CA16391-JUN15

Box 20157, 131 St. Paul St.
Belleville, ON
K8N 5V1,

Copy: #1

Phone: 613-962-5454
Fax:pdf-ID Plant

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field Free Chlorine mg/L	Total Coliform cfu/100mL	E. Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date	---	---	---	09-Jun-15	09-Jun-15	09-Jun-15
2: Analysis Start Time	---	---	---	15:25	15:25	14:45
3: Analysis Approval Date	--	--	--	10-Jun-15	10-Jun-15	11-Jun-15
4: Analysis Approval Time	--	--	--	14:03	14:03	13:11
5: MAC	--	--	--	0	0	---
6: 26F9D RW RW-QMS: Raw Water 26F9D RW	08-Jun-15 09:15	17.0	---	2	0	11
7: 6712 NR DW DW1-QMS Daycare 6712 NR/DW	08-Jun-15 08:59	17.0	1.7	0	0	0
8: 13481 NR/DW DW3-QMS: Boys wshrm Drinking Fountain 13481 NR/DW	08-Jun-15 09:10	17.0	1.44	0	0	0

Method Descriptions

Parameter	Description	SGS Method Code
E. Coli	E.Coli by membrane filtration on DC media	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count by membrane filtration	ME-CA-[ENV]MIC-LAK-AN-005
Total Coliform	Total Coliform by membrane filtration using DC media	ME-CA-[ENV]MIC-LAK-AN-001


 Carrie Greenlaw
 Project Specialist
 Environmental Services, Analytical