



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - KOL 2HO
Phone: 705-652-2000 FAX: 705-652-6365

Not Reportable as per Chain of Custody
Works #: 1156

Project : PO#017018

29-October-2015

OCWA-Trent Valley (Quinte Mohawk School)

Attn : James Taylor

Date Rec. : 27 October 2015

LR Report: CA16661-OCT15

Box 20157, 131 St. Paul St.
Belleville, ON
K8N 5V1,

Copy: #1

Phone: 613-962-5454
Fax:pdf-ID Plant

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field Free Chlorine mg/L	Total Coliform cfu/100mL	E. Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	27-Oct-15	27-Oct-15	27-Oct-15
2: Analysis Start Time		---	---	15:00	15:00	14:10
3: Analysis Approval Date		--	--	28-Oct-15	28-Oct-15	29-Oct-15
4: Analysis Approval Time		--	--	16:21	16:21	11:43
5: MAC		--	--	0	0	---
6: 26F9D RW RW-QMS: Raw Water 26F9D RW	26-Oct-15 07:59	13.0	---	1	0	400
7: 6712 NR DW DW1-QMS Daycare 6712 NR/DW	26-Oct-15 08:23	13.0	1.12	0	0	0
8: 13480 NR/DW DW3-QMS: Girls Fountain 13480 NR/DW	26-Oct-15 08:32	13.0	1.16	0	0	38

Method Descriptions

Parameter	Description	SGS Method Code
E. Coli	E.Coli by membrane filtration on DC media	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count by membrane filtration	ME-CA-[ENV]MIC-LAK-AN-005
Total Coliform	Total Coliform by membrane filtration using DC media	ME-CA-[ENV]MIC-LAK-AN-001

Carrie Greenlaw
Project Specialist
Environmental Services, Analytical