



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 1156

Project : PO#017018

30-July-2015

OCWA-Trent Valley (Quinte Mohawk School)

Attn : James Taylor

Date Rec. : 28 July 2015

LR Report: CA16663-JUL15

Box 20157, 131 St. Paul St.
Belleville, ON
K8N 5V1,

Copy: #1

Phone: 613-962-5454
Fax:pdf-ID Plant

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field Free Chlorine mg/L	Total Coliform cfu/100mL	E. Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	28-Jul-15	28-Jul-15	28-Jul-15
2: Analysis Start Time		---	---	13:40	13:40	13:10
3: Analysis Approval Date		--	--	30-Jul-15	30-Jul-15	30-Jul-15
4: Analysis Approval Time		--	--	09:08	09:08	10:52
5: MAC		--	--	0	0	---
6: 26F9D RW RW-QMS: Raw Water Tap	27-Jul-15 09:17	22.0	---	0	0	8
7: 6712 NR DW DW1-QMS Daycare	27-Jul-15 09:53	22.0	0.70	0	0	1
8: 6711 NR DW DW3-Kitchen Tap	27-Jul-15 10:07	22.0	0.83	0	0	19

NR - Not reportabl e under appl i cabl e Provi nci al dri nki ng wat er regul ati ons as per cli ent.

Method Descri pti ons

Parameter	Description	SGS Method Code
E. Coli	E.Coli by membrane filtration on DC media	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count by membrane filtration	ME-CA-[ENV]MIC-LAK-AN-005
Total Coliform	Total Coliform by membrane filtration using DC media	ME-CA-[ENV]MIC-LAK-AN-001

Kimberley Didsbury
Project Specialist
Environmental Services, Analytical