

SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - KOL 2H0
Phone: 705-652-2000 FAX: 705-652-6365

13-August-2015

OCWA-Trent Valley (Quinte Mohawk School)

Attn : James Taylor

Date Rec. : 11 August 2015
LR Report: CA17637-AUG15

Box 20157, 131 St. Paul St.
Belleville, ON
K8N 5V1,

Copy: #1

Phone: 613-962-5454
Fax:pdf-ID Plant

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field Free Chlorine mg/L	Total Coliform cfu/100mL	E. Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	11-Aug-15	11-Aug-15	11-Aug-15
2: Analysis Start Time		---	---	12:30	12:30	12:00
3: Analysis Approval Date		--	--	13-Aug-15	13-Aug-15	13-Aug-15
4: Analysis Approval Time		--	--	10:56	10:56	11:23
5: MAC		--	--	0	0	---
6: 26F9D RW RW-QMS: Raw Water 26F9D RW	10-Aug-15 09:11	19.0	---	0	0	1
7: 6712 NR DW DW1-QMS Daycare 6712 NR/DW	10-Aug-15 09:37	19.0	0.81	0	0	0
8: 6711 NR DW DW3-Kitchen Tap 6711 NR/DW	10-Aug-15 09:45	19.0	0.90	0	0	4

Method Descriptions

Parameter	Description	SGS Method Code
E. Coli	E.Coli by membrane filtration on DC media	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count by membrane filtration	ME-CA-[ENV]MIC-LAK-AN-005
Total Coliform	Total Coliform by membrane filtration using DC media	ME-CA-[ENV]MIC-LAK-AN-001


 Carrie Greenlaw
 Project Specialist
 Environmental Services, Analytical