



**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - K0L 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

**Not Reportable as per Chain of Custody  
Works #: 1156**

**Project : PO#017018**

10-July-2015

**OCWA-Trent Valley (Quinte Mohawk School)**

Attn : James Taylor

**Date Rec. : 08 July 2015  
LR Report: CA17850-JUL15**

Box 20157, 131 St. Paul St.  
Belleville, ON  
K8N 5V1,

**Copy: #1**

Phone: 613-962-5454  
Fax:pdf-ID Plant

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field Free Chlorine mg/L	Total Coliform cfu/100mL	E. Coli Heterotrophic cfu/100mL	Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	08-Jul-15	08-Jul-15	08-Jul-15
2: Analysis Start Time		---	---	13:55	13:55	13:45
3: Analysis Approval Date		--	--	09-Jul-15	09-Jul-15	10-Jul-15
4: Analysis Approval Time		--	--	15:11	15:11	12:28
5: MAC		--	--	0	0	---
6: 26F9D RW RW-QMS: Raw Water 26F9D RW	07-Jul-15 09:07	16.0	---	0	0	7
7: 6712 NR DW DW1-QMS Daycare 6712 NR/DW	07-Jul-15 09:48	16.0	1.39	0	0	0
8: 1EC6A NR DW DW2-QMS Staff Room Tap 1EC6A NR/DW	07-Jul-15 09:55	16.0	1.5	0	0	0

### Method Descriptions

Parameter	Description	SGS Method Code
E. Coli	E.Coli by membrane filtration on DC media	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count by membrane filtration	ME-CA-[ENV]MIC-LAK-AN-005
Total Coliform	Total Coliform by membrane filtration using DC media	ME-CA-[ENV]MIC-LAK-AN-001

  
 Carrie Greenlaw  
 Project Specialist  
 Environmental Services, Analytical