



Not Reportable as per Chain of Custody
Works #: 1156

Project : PO#017018

SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - KOL 2HO
Phone: 705-652-2000 FAX: 705-652-6365

23-July-2015

OCWA-Trent Valley (Quinte Mohawk School)

Attn : James Taylor

Date Rec. : 21 July 2015
LR Report: CA18517-JUL15

Box 20157, 131 St. Paul St.
Belleville, ON
K8N 5V1,

Copy: #1

Phone: 613-962-5454
Fax:pdf-ID Plant

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field Free Chlorine mg/L	Total Coliform cfu/100mL	E. Coli Heterotrophic cfu/100mL	Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	21-Jul-15	21-Jul-15	21-Jul-15
2: Analysis Start Time		---	---	16:20	16:20	15:40
3: Analysis Approval Date		--	--	23-Jul-15	23-Jul-15	23-Jul-15
4: Analysis Approval Time		--	--	14:08	14:08	14:08
5: MAC		--	--	0	0	---
6: 26F9D RW RW-QMS: Raw Water 26F9D RW	20-Jul-15 08:42	19.0	---	0	0	8
7: 6712 NR DW DW1-QMS Daycare 6712 NR/DW	20-Jul-15 08:51	19.0	0.64	0	0	15
8: 13480 NR/DW DW3-QMS: Fountain Water Girls Bathroom 13480 NR/DW	20-Jul-15 09:02	19.0	0.67	0	0	59

Method Descriptions

Parameter	Description	SGS Method Code
E. Coli	E.Coli by membrane filtration on DC media	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count by membrane filtration	ME-CA-[ENV]MIC-LAK-AN-005
Total Coliform	Total Coliform by membrane filtration using DC media	ME-CA-[ENV]MIC-LAK-AN-001


 Carrie Greenlaw
 Project Specialist
 Environmental Services, Analytical