



**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - K0L 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

**Project :** PO#017018

January-02-13

**OCWA-Trent Valley (Quinte Mohawk School)**

Attn : Steve Arnold

**Date Rec. :** 27 December 2012  
**LR Report:** CA14637-DEC12

Box 20157, 131 St. Paul St.  
Belleville, ON  
K8N 5V1,

**Copy:** #1

Phone: 613-962-5454  
Fax:pdf-ID Plant

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Free Chlorine mg/L	Total Coliform cfu/100mL	E. Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	27-Dec-12	27-Dec-12	27-Dec-12
2: Analysis Start Time		---	---	17:15	17:15	16:50
3: Analysis Approval Date		--	--	28-Dec-12	28-Dec-12	29-Dec-12
4: Analysis Approval Time		--	--	16:26	16:26	14:14
5: MAC		--	--	0	0	---
6: NR/DW Fountain Outside Daycare	27-Dec-12 07:58	6.0	0.51	0	0	0
7: 1ec6a NR/DW QMS Staff Lunch Room Tap	27-Dec-12 08:05	6.0	0.93	0	0	0

Total and/or Free Residual Chlorine was not analyzed by SGS Environmental Services.



*Carrie Greenlaw*  
Carrie Greenlaw  
Project Specialist  
Environmental Services, Analytical