



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Project : PO#017018

January-02-13

OCWA-Trent Valley (Quinte Mohawk School)

Attn : Steve Arnold

Date Rec. : 28 December 2012
LR Report: CA14656-DEC12

Box 20157, 131 St. Paul St.
Belleville, ON
K8N 5V1,

Copy: #1

Phone: 613-962-5454
Fax:pdf-ID Plant

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Free Chlorine mg/L	Total Coliform cfu/100mL	E. Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	28-Dec-12	28-Dec-12	28-Dec-12
2: Analysis Start Time		---	---	14:35	14:35	14:30
3: Analysis Approval Date		--	--	02-Jan-13	02-Jan-13	02-Jan-13
4: Analysis Approval Time		--	--	09:34	09:34	09:34
5: MAC		--	--	0	0	---
6: 26F9D RW QMS: Raw Water Tap	28-Dec-12 12:16	15.0	---	0	0	415
7: 6712 NR/DW QMS Daycare	28-Dec-12 12:08	15.0	1.98	0	0	0
8: 1F430 NR/DW Room 32	28-Dec-12 12:14	15.0	2.01	0	0	0

Total and/or Free Residual Chlorine was not analyzed by SGS Environmental Services.



Carrie Greenlaw
Project Specialist
Environmental Services, Analytical