



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - KOL 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Not Reportable as per Chain of Custody
Works #: 1156

Project : PO#017018

08-January-2015

OCWA-Trent Valley (Quinte Mohawk School)

Attn : James Taylor

Date Rec. : 06 January 2015
LR Report: CA16024-JAN15

Box 20157, 131 St. Paul St.
Belleville, ON
K8N 5V1,

Copy: #1

Phone: 613-962-5454
Fax:pdf-ID Plant

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field Total Chlorine mg/L	Field Free Chlorine mg/L	Total Coliform cfu/100mL	E. Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	---	06-Jan-15	06-Jan-15	06-Jan-15
2: Analysis Start Time		---	---	---	13:00	13:00	12:20
3: Analysis Approval Date		--	---	--	07-Jan-15	07-Jan-15	08-Jan-15
4: Analysis Approval Time		--	---	--	17:15	17:15	11:08
5: MAC		--	---	--	0	0	---
6: 26F9D RW RW-QMS: Raw Water 26F9D RW	05-Jan-15 08:45	7.0	---	---	0	0	19
7: 6712 NR DW DW1-QMS Daycare 6712 NR/DW	05-Jan-15 08:30	7.0	1.19	1.04	0	0	3
8: 1EC6A NR DW DW2-QMS Staff Room Tap 1EC6A NR/DW	05-Jan-15 08:15	7.0	1.14	0.93	0	0	2

Method Descriptions

	Parameter	Description	SGS Method Code
1	E. Coli	E.Coli by membrane filtration on DC media	ME-CA-[ENV]MIC-LAK-AN-001
2	Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count by membrane filtration	ME-CA-[ENV]MIC-LAK-AN-005
3	Total Coliform	Total Coliform by membrane filtration using DC media	ME-CA-[ENV]MIC-LAK-AN-001

Carrie Greenlaw
Project Specialist
Environmental Services, Analytical