



Not Reportable as per Chain of Custody
Works #: 1156

Project : PO#017018

SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

06-March-2014

OCWA-Trent Valley (Quinte Mohawk School)

Attn : James Taylor

Date Rec. : 04 March 2014
LR Report: CA16063-MAR14

Box 20157, 131 St. Paul St.
Belleville, ON
K8N 5V1,

Copy: #1

Phone: 613-962-5454
Fax:pdf-ID Plant

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Temperature Time Upon Receipt °C	Total Chlorine mg/L	Free Chlorine mg/L	Total Coliform cfu/100mL	E. Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date	---	---	---	04-Mar-14	04-Mar-14	04-Mar-14
2: Analysis Start Time	---	---	---	14:50	14:50	14:15
3: Analysis Approval Date	--	--	--	06-Mar-14	06-Mar-14	06-Mar-14
4: Analysis Approval Time	--	--	--	09:12	09:12	13:47
5: MAC	--	--	--	0	0	---
6: 26F9D RW RW-QMS: Raw Water 26F9D RW	03-Mar-14 09:12	3.0	---	0	0	30
7: 6712 NR DW DW1-QMS Daycare 6712 NR/DW	03-Mar-14 09:35	3.0	1.80	1.59	0	0
8: 1EC6A NR DW DW2-QMS Staff Room Tap 1EC6A NR/DW	03-Mar-14 09:45	3.0	1.69	1.50	0	0

Total and/or Free Residual Chlorine was not analyzed by SGS Environmental Services.



Carrie Greenlaw
Project Specialist
Environmental Services, Analytical