



Not Reportable as per Chain of Custody  
Works #: 1156

Project : PO#017018

**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - K0L 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

08-May-2014

**OCWA-Trent Valley (Quinte Mohawk School)**

Attn : James Taylor

Date Rec. : 06 May 2014

LR Report: CA16096-MAY14

Box 20157, 131 St. Paul St.  
Belleville, ON  
K8N 5V1,

Copy: #1

Phone: 613-962-5454  
Fax:pdf-ID Plant

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Temperature Time Upon Receipt °C	Total Chlorine mg/L	Free Chlorine mg/L	Total Coliform cfu/100mL	E. Coli Heterotrophic cfu/100mL	Plate Count (HPC) cfu/1mL
1: Analysis Start Date	---	---	---	06-May-14	06-May-14	06-May-14
2: Analysis Start Time	---	---	---	11:35	11:35	11:05
3: Analysis Approval Date	--	---	--	07-May-14	07-May-14	08-May-14
4: Analysis Approval Time	--	---	--	15:32	15:32	10:40
5: MAC	--	---	--	0	0	---
6: 26F9D RW RW-QMS: Raw Water 26F9D RW	05-May-14 08:00	13.0	---	0	0	8
7: 6712 NR DW DW1-QMS Daycare 6712 NR/DW	05-May-14 08:15	13.0	1.30	1.18	0	0
8: 1EC6A NR DW DW2-QMS Staff Room Tap 1EC6A NR/DW	05-May-14 08:10	13.0	1.55	1.40	0	0

Total and/or Free Residual Chlorine was not analyzed by SGS Environmental Services.

Carrie Greenlaw  
Project Specialist  
Environmental Services, Analytical