

SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
 Lakefield - Ontario - K0L 2H0
 Phone: 705-652-2000 FAX: 705-652-6365

Project : PO#017018

08-April-2013

OCWA-Trent Valley (Quinte Mohawk School)

Attn : James Taylor

Date Rec. : 05 April 2013

LR Report: CA16108-APR13

Box 20157, 131 St. Paul St.
 Belleville, ON
 K8N 5V1,

Copy: #1

Phone: 613-962-5454
 Fax:pdf-ID Plant

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temp Upon Receipt °C	ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	HPC cfu/1mL
1: Analysis Start Date		---	---	05-Apr-13	05-Apr-13	05-Apr-13
2: Analysis Start Time		---	---	11:40	11:40	11:00
3: Analysis Approval Date		--	--	08-Apr-13	08-Apr-13	08-Apr-13
4: Analysis Approval Time		--	--	14:34	14:34	14:34
5: MAC		--	--	0	0	---
6: 1F430 NR/DW Classroom #18 Mr. Rieds	04-Apr-13 10:23	10.0	1.59	0	0	0

Total and/or Free Residual Chlorine was not analyzed by SGS Environmental Services.
 NR - Not reportable under applicable drinking water regulations as per client.

 Kimberley Didsbury
 Project Specialist
 Environmental Services, Analytical