

SGS Canada Inc.

P.O. Box 4300 - 185 Concession St. Lakefield - Ontario - KOL 2HO

Phone: 705-652-2000 FAX: 705-652-6365

Not Reportable as per Chain of Custody

Works #: 1156

Project: PO#017018

21-November-2013

Date Rec.: 19 November 2013 LR Report: CA16122-NOV13

Copy: #1

OCWA-Trent Valley (Quinte Mohawk School)

Attn: James Taylor

Box 20157, 131 St. Paul St. Belleville, ON K8N 5V1,

Phone: 613-962-5454 Fax:pdf-ID Plant

CERTIFICATE OF ANALYSIS Final Report

Sample ID	Sample Date & Te Time Upo	mperature on Receipt °C	FreeTo Chlorine mg/L	otal Coliform cfu/100mL	E. Coli I cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				19-Nov-13	19-Nov-13	19-Nov-13
2: Analysis Start Time				16:00	16:00	15:40
3: Analysis Approval Date				21-Nov-13	21-Nov-13	21-Nov-13
4: Analysis Approval Time				11:53	11:53	13:38
5: MAC				0	0	
6: 26F9D RW RW-QMS: Raw Water 26F9D RW	18-Nov-13 09:38	3.0		0	0	30
7: 6712 NR DW DW1-QMS Daycare 6712 NR/DW	18-Nov-13 09:55	3.0	0.91	0	0	0
8: 1EC6A NR DW DW2-QMS Staff Room Tap 1EC6A NR/DW	18-Nov-13 10:04	3.0	0.86	0	0	0

Total and/or Free Residual Chlorine was not analyzed by SGS Environmental Services.

Project Specialist

Environmental Services, Analytical