



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Project : PO#017018

April-12-13

OCWA-Trent Valley (Quinte Mohawk School)

Attn : James Taylor

Date Rec. : 09 April 2013
LR Report: CA16164-APR13

Box 20157, 131 St. Paul St.
Belleville, ON
K8N 5V1,

Copy: #1

Phone: 613-962-5454
Fax:pdf-ID Plant

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Free Chlorine mg/L	Total Coliform cfu/100mL	E. Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	09-Apr-13	09-Apr-13	09-Apr-13
2: Analysis Start Time		---	---	11:50	11:50	11:15
3: Analysis Approval Date		---	---	11-Apr-13	11-Apr-13	11-Apr-13
4: Analysis Approval Time		---	---	12:02	12:02	12:02
5: MAC		---	---	0	0	---
6: 6712 NR/DW QMS Daycare	08-Apr-13 11:28	13.0	1.30	0	0	0
7: 1F432 NR/DW QMS Fountain Water: Front Entrance	08-Apr-13 11:51	13.0	1.21	0	0	0

Total and/or Free Residual Chlorine was not analyzed by SGS Environmental Services.



Carrie Greenlaw
Project Specialist
Environmental Services, Analytical