



SGS Canada Inc.
P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - KOL 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Not Reportable as per Chain of Custody Works #: 1156

Project : PO#017018

09-October-2014

OCWA-Trent Valley (Quinte Mohawk School)

Attn : James Taylor

Date Rec. : 07 October 2014

LR Report: CA16215-OCT14

Box 20157, 131 St. Paul St.
Belleville, ON
K8N 5V1,

Copy: #1

Phone: 613-962-5454
Fax:pdf-ID Plant

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Free Chlorine mg/L	Total Coliform cfu/100mL	E. Coli Heterotrophic cfu/100mL	Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	07-Oct-14	07-Oct-14	07-Oct-14
2: Analysis Start Time		---	---	12:55	12:55	12:25
3: Analysis Approval Date		--	--	09-Oct-14	09-Oct-14	09-Oct-14
4: Analysis Approval Time		--	--	08:29	08:29	11:43
5: MAC		--	--	0	0	---
6: 26F9D RW RW-QMS: Raw Water 26F9D RW	06-Oct-14 08:15	13.0	---	0	0	0
7: 6712 NR DW DW1-QMS Daycare 6712 NR/DW	06-Oct-14 08:53	13.0	1.46	0	0	0
8: 1EC6A NR DW DW2-QMS Staff Room Tap 1EC6A NR/DW	06-Oct-14 09:02	13.0	1.44	0	0	0

Total and/or Free Residual Chlorine was not analyzed by SGS Environmental Services.

Method Descriptions

	Parameter	Unit	Description	SGS Method Code
1	E. Coli	cfu/100mL	E.Coli by membrane filtration on DC media	ME-CA-[ENV]MIC-LAK-AN-001
2	Heterotrophic Plate Count (HPC)	cfu/1mL	Heterotrophic Plate Count by membrane filtration	ME-CA-[ENV]MIC-LAK-AN-005
3	Total Coliform	cfu/100mL	Total Coliform by membrane filtration using DC media	ME-CA-[ENV]MIC-LAK-AN-001


Carrie Greenlaw
Project Specialist
Environmental Services, Analytical