

**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.  
 Lakefield - Ontario - KOL 2H0  
 Phone: 705-652-2000 FAX: 705-652-6365

**Project :** PO#017018

January-10-13

**OCWA-Trent Valley (Quinte Mohawk School)**

Attn : Steve Arnold

**Date Rec. :** 08 January 2013  
**LR Report:** CA16218-JAN13

Box 20157, 131 St. Paul St.  
 Belleville, ON  
 K8N 5V1,

**Copy:** #1

Phone: 613-962-5454  
 Fax:pdf-ID Plant

## CERTIFICATE OF ANALYSIS

### Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Free Chlorine mg/L	Total Coliform cfu/100mL	E. Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	08-Jan-13	08-Jan-13	08-Jan-13
2: Analysis Start Time		---	---	11:00	11:00	10:40
3: Analysis Approval Date		--	--	09-Jan-13	09-Jan-13	10-Jan-13
4: Analysis Approval Time		--	--	12:49	12:49	09:26
5: MAC		--	--	0	0	---
6: 6712 NR/DW QMS Daycare	07-Jan-13 10:42	6.0	1.50	0	0	2
7: lecba NR/DW QMS-Staff Room Tap	07-Jan-13 10:53	6.0	1.34	0	0	1

Total and/or Free Residual Chlorine was not analyzed by SGS Environmental Services.



*Carrie Greenlaw*  
 Carrie Greenlaw  
 Project Specialist  
 Environmental Services, Analytical