



**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - KOL 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

**Project :** PO#017018

May-09-13

**OCWA-Trent Valley (Quinte Mohawk School)**

Attn : James Taylor

**Date Rec. :** 07 May 2013

**LR Report:** CA16247-MAY13

Box 20157, 131 St. Paul St.  
Belleville, ON  
K8N 5V1,

**Copy:** #1

Phone: 613-962-5454  
Fax:pdf-ID Plant

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Free Chlorine mg/L	Total Coliform cfu/100mL	E. Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	07-May-13	07-May-13	07-May-13
2: Analysis Start Time		---	---	13:00	13:00	11:55
3: Analysis Approval Date		--	--	09-May-13	09-May-13	09-May-13
4: Analysis Approval Time		--	--	11:12	11:12	12:14
5: MAC		--	--	0	0	---
6: 26F9D RW QMS: Raw Water Tap	06-May-13 10:39	15.0	---	0	0	9
7: 1ec6a NR/DW QMS Staff Room Tap	06-May-13 11:28	15.0	1.22	0	0	0
8: 6712 NR/DW QMS Daycare	06-May-13 11:19	15.0	1.24	0	0	0

Total and/or Free Residual Chlorine was not analyzed by SGS Environmental Services.

Carrie Greenlaw  
Project Specialist  
Environmental Services, Analytical