



Not Reportable as per Chain of Custody Works #: 1156

Project : PO#017018

SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - KOL 2H0
Phone: 705-652-2000 FAX: 705-652-6365

11-September-2014

OCWA-Trent Valley (Quinte Mohawk School)

Attn : James Taylor

Date Rec. : 09 September 2014
LR Report: CA16257-SEP14

Box 20157, 131 St. Paul St.
Belleville, ON
K8N 5V1,

Copy: #1

Phone: 613-962-5454
Fax:pdf-ID Plant

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Total Chlorine mg/L	Free Chlorine mg/L	Total Coliform cfu/100mL	E. Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	---	09-Sep-14	09-Sep-14	09-Sep-14
2: Analysis Start Time		---	---	---	11:45	11:45	11:15
3: Analysis Approval Date		--	---	--	11-Sep-14	11-Sep-14	11-Sep-14
4: Analysis Approval Time		--	---	--	08:27	08:27	11:26
5: MAC		--	---	--	0	0	---
6: 26F9D RW RW-QMS: Raw Water 26F9D RW	08-Sep-14 08:40	20.0	---	---	0	0	26
7: 6712 NR DW DW1-QMS Daycare 6712 NR/DW	08-Sep-14 08:30	20.0	1.64	1.44	0	0	1
8: 1F432 NR/DW DW3-QMS: Fountain Water Front Entrance 1F432 NR/DW	08-Sep-14 08:15	20.0	0.77	0.71	0	0	6

Total and/or Free Residual Chlorine was not analyzed by SGS Environmental Services.

Carrie Greenlaw
Project Specialist
Environmental Services, Analytical



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - KOL 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Not Reportable as per Chain of Custody

Works #: 1156

Project : PO#017018

LR Report : CA16257-SEP14

Method Descriptions

	Parameter	Unit	Low Limit	Description	SGS Method Code
1	E.Coli	cfu/100mL	0	E.Coli by membrane filtration on DC media	ME-CA-[ENV]MIC-LAK-AN-001
2	HPC	cfu/1mL	0	Heterotrophic Plate Count by membrane filtration	ME-CA-[ENV]MIC-LAK-AN-005
3	Total Coliform	cfu/100mL	0	Total Coliform by membrane filtration using DC media	ME-CA-[ENV]MIC-LAK-AN-001