



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - KOL 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Not Reportable as per Chain of Custody
Works #: 1156

Project : PO#017018

13-January-2014

OCWA-Trent Valley (Quinte Mohawk School)

Attn : James Taylor

Date Rec. : 09 January 2014
LR Report: CA16353-JAN14

Box 20157, 131 St. Paul St.
Belleville, ON
K8N 5V1,

Copy: #1

Phone: 613-962-5454
Fax:pdf-ID Plant

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Sodium mg/L
1: Analysis Start Date		---	10-Jan-14
2: Analysis Start Time		---	08:35
3: Analysis Approval Date		--	13-Jan-14
4: Analysis Approval Time		--	12:07
5: MAC		--	20*
6: AO/OG		---	200
7: MDL		---	0.01
8: RW Raw	08-Jan-14 13:02	9.0	21.0

MAC - Maximum Acceptable Concentration
AO/OG - Aesthetic Objective / Operational Guideline
MDL - SGS Method Detection Limit
*Sodium > 20mg/L is an indicator of adverse water quality.

Carrie Greenlaw
Project Specialist
Environmental Services, Analytical