



Not Reportable as per Chain of Custody
Works #: 1156

Project : PO#017018

SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

12-December-2013

OCWA-Trent Valley (Quinte Mohawk School)

Attn : James Taylor

Date Rec. : 10 December 2013
LR Report: CA16435-DEC13

Box 20157, 131 St. Paul St.
Belleville, ON
K8N 5V1,

Copy: #1

Phone: 613-962-5454
Fax:pdf-ID Plant

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Free Chlorine mg/L	Total Coliform cfu/100mL	E. Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	10-Dec-13	10-Dec-13	10-Dec-13
2: Analysis Start Time		---	---	11:55	11:55	11:20
3: Analysis Approval Date		--	--	11-Dec-13	11-Dec-13	12-Dec-13
4: Analysis Approval Time		--	--	11:56	11:56	10:51
5: MAC		--	--	0	0	---
6: 26F9D RW RW-QMS: Raw Water 26F9D RW	09-Dec-13 10:49	7.0	---	0	0	102
7: 6712 NR/DW DW1-QMS Daycare (Fountain Outside) 6712 NR/DW	09-Dec-13 11:00	7.0	1.07	0	0	0
8: 13481 NR/DW DW3-QMS:Fountain Water: Boys Bathroom 13481 NR/DW	09-Dec-13 11:07	7.0	0.95	0	0	1

Total and/or Free Residual Chlorine was not analyzed by SGS Environmental Services.

Carrie Greenlaw
Project Specialist
Environmental Services, Analytical