

SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - KOL 2H0
Phone: 705-652-2000 FAX: 705-652-6365

29-January-2015

OCWA-Trent Valley (Quinte Mohawk School)

Attn : James Taylor

Date Rec. : 27 January 2015
LR Report: CA16540-JAN15

Box 20157, 131 St. Paul St.
Belleville, ON
K8N 5V1,

Copy: #1

Phone: 613-962-5454
Fax:pdf-ID Plant

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Temperature Time Upon Receipt °C	Field Total Chlorine mg/L	Field Free Chlorine mg/L	Total Coliform cfu/100mL	E. Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date	---	---	---	27-Jan-15	27-Jan-15	27-Jan-15
2: Analysis Start Time	---	---	---	14:05	14:05	13:45
3: Analysis Approval Date	--	---	--	28-Jan-15	28-Jan-15	29-Jan-15
4: Analysis Approval Time	--	---	--	14:43	14:43	11:21
5: MAC	--	---	--	0	0	---
6: 26F9D RW RW-QMS: Raw Water 26F9D RW	26-Jan-15 08:30	5.0	---	0	0	8
7: 6712 NR DW DW1-QMS Daycare 6712 NR/DW	26-Jan-15 08:15	5.0	2.03	1.78	0	0
8: 6711 NR DW Kitchen Sink 6711 NR/DW	26-Jan-15 08:00	5.0	1.73	1.52	0	0

Method Descriptions

	Parameter	Description	SGS Method Code
1	E. Coli	E.Coli by membrane filtration on DC media	ME-CA-[ENV]MIC-LAK-AN-001
2	Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count by membrane filtration	ME-CA-[ENV]MIC-LAK-AN-005
3	Total Coliform	Total Coliform by membrane filtration using DC media	ME-CA-[ENV]MIC-LAK-AN-001


 Carrie Greenlaw
 Project Specialist
 Environmental Services, Analytical