

SGS Canada Inc.

P.O. Box 4300 - 185 Concession St. Lakefield - Ontario - KOL 2HO

Phone: 705-652-2000 FAX: 705-652-6365

Not Reportable as per Chain of Custody

Works #: 1156

**Project:** PO#017018

June-13-13

**Date Rec.**: 11 June 2013 **LR Report: CA16579-JUN13** 

**Copy:** #1

**OCWA-Trent Valley (Quinte Mohawk School)** 

Attn : James Taylor

Box 20157, 131 St. Paul St. Belleville, ON K8N 5V1,

Phone: 613-962-5454 Fax:pdf-ID Plant

## CERTIFICATE OF ANALYSIS Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Free Chlorine mg/L	Total Coliform cfu/100mL	E. Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				11-Jun-13	11-Jun-13	11-Jun-13
2: Analysis Start Time				15:10	15:10	14:40
3: Analysis Approval Date				12-Jun-13	12-Jun-13	13-Jun-13
4: Analysis Approval Time				15:09	15:09	15:14
5: MAC				0	0	
6: 6712 NR/DW DW1-QMS Daycare	10-Jun-13 10:27	13.0	1.25	0	0	2
7: 13480 NR/DW DW2-QMS: Fountain Water: Girls Bathroom	10-Jun-13 10:35	13.0	1.10	0	0	1

Total and/or Free Residual Chlorine was not analyzed by SGS Environmental Services.

Carrie Greenlaw

Project Specialist

Environmental Services, Analytical