



SGS Canada Inc.
P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Project : PO#017018

February-22-13

OCWA-Trent Valley (Quinte Mohawk School)

Attn : James Taylor

Date Rec. : 20 February 2013
LR Report: CA16665-FEB13

Box 20157, 131 St. Paul St.
Belleville, ON
K8N 5V1,

Copy: #1

Phone: 613-962-5454
Fax:pdf-ID Plant

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Free Chlorine mg/L	Total Coliform cfu/100mL	E. Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	20-Feb-13	20-Feb-13	20-Feb-13
2: Analysis Start Time		---	---	14:15	14:15	13:50
3: Analysis Approval Date		--	--	21-Feb-13	21-Feb-13	22-Feb-13
4: Analysis Approval Time		--	--	16:07	16:07	12:52
5: MAC		--	--	0	0	---
6: 6712 NR/DW QMS Daycare	19-Feb-13 10:09	6.0	1.31	0	0	1
7: 1ec6a NR/DW QMS Staff Room Tap	19-Feb-13 10:17	6.0	1.29	0	0	0

Total and/or Free Residual Chlorine was not analyzed by SGS Environmental Services.



Carrie Greenlaw
Project Specialist
Environmental Services, Analytical