



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Not Reportable as per Chain of Custody
Works #: 1156

Project : PO#017018

May-16-13

OCWA-Trent Valley (Quinte Mohawk School)

Attn : James Taylor

Date Rec. : 14 May 2013

LR Report: CA16685-MAY13

Box 20157, 131 St. Paul St.
Belleville, ON
K8N 5V1,

Copy: #1

Phone: 613-962-5454
Fax:pdf-ID Plant

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Free Chlorine mg/L	Total Coliform cfu/100mL	E. Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	14-May-13	14-May-13	14-May-13
2: Analysis Start Time		---	---	12:50	12:50	12:20
3: Analysis Approval Date		--	--	16-May-13	16-May-13	16-May-13
4: Analysis Approval Time		--	--	09:21	09:21	11:02
5: MAC		--	--	0	0	---
6: 6712 NR/DW QMS Daycare	13-May-13 09:07	12.0	1.36	0	0	0
7: 1F432 NR/DW QMS: Fountain Water: Front Entrance	13-May-13 09:13	12.0	0.76	0	0	2

Total and/or Free Residual Chlorine was not analyzed by SGS Environmental Services.

Carrie Greenlaw
Project Specialist
Environmental Services, Analytical