



SGS Canada Inc.
 P.O. Box 4300 - 185 Concession St.
 Lakefield - Ontario - K0L 2H0
 Phone: 705-652-2000 FAX: 705-652-6365

Not Reportable as per Chain of Custody Works #: 1156

Project : PO#017018

03-October-2013

OCWA-Trent Valley (Quinte Mohawk School)

Attn : James Taylor

Date Rec. : 01 October 2013
LR Report: CA17150-OCT13

Box 20157, 131 St. Paul St.
 Belleville, ON
 K8N 5V1,

Copy: #1

Phone: 613-962-5454
 Fax:pdf-ID Plant

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Free Chlorine mg/L	Total Coliform cfu/100mL	E. Coli Heterotrophic cfu/100mL	Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	01-Oct-13	01-Oct-13	01-Oct-13
2: Analysis Start Time		---	---	15:25	15:25	14:50
3: Analysis Approval Date		--	--	03-Oct-13	03-Oct-13	03-Oct-13
4: Analysis Approval Time		--	--	12:10	12:10	12:27
5: MAC		--	--	0	0	---
6: 26F9D RW RW-QMS: Raw Water	30-Sep-13 10:53	14.0	---	0	0	11
7: 6712 NR DW DW1-QMS Daycare 6712	30-Sep-13 11:10	14.0	1.31	0	0	1
8: 1F432 NR DW DW3 QMS: Fountain Water-Front Entrance	30-Sep-13 11:19	14.0	1.30	0	0	0

Total and/or Free Residual Chlorine was not analyzed by SGS Environmental Services.


 Carrie Greenlaw
 Project Specialist
 Environmental Services, Analytical