



**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - K0L 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

**Works #:** 1156

**Project :** PO#017018

02-October-2015

**OCWA-Trent Valley (Quinte Mohawk School)**

Attn : James Taylor

**Date Rec. :** 30 September 2015

**LR Report:** CA17156-SEP15

Box 20157, 131 St. Paul St.  
Belleville, ON  
K8N 5V1,

**Copy:** #1

Phone: 613-962-5454  
Fax:pdf-ID Plant

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temp Upon Receipt °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	HPC cfu/1mL
1: Analysis Start Date		---	---	30-Sep-15	30-Sep-15	30-Sep-15
2: Analysis Start Time		---	---	15:00	15:00	13:50
3: Analysis Approval Date		--	--	01-Oct-15	01-Oct-15	02-Oct-15
4: Analysis Approval Time		--	--	15:44	15:44	11:17
5: MAC		--	--	0	0	---
6: 26F9D RW RW-QMS: Raw Water 26F9D RW	29-Sep-15 08:53	8.0	---	8	0	26
7: 6712 NR DW DW1-QMS Daycare 6712 NR/DW	29-Sep-15 09:06	8.0	1.52	0	0	0
8: 6711 NR DW DW2-Kitchen NR/DW	29-Sep-15 09:17	8.0	1.41	0	0	0

NR - Not reportabl e under appl icabl e Provi nci al dri nki ng water regul ati ons as per cli ent.

### Method Descri pti ons

Parameter	Description	SGS Method Code
E. Coli	E.Coli by membrane filtration on DC media	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count by membrane filtration	ME-CA-[ENV]MIC-LAK-AN-005
Total Coliform	Total Coliform by membrane filtration using DC media	ME-CA-[ENV]MIC-LAK-AN-001

**Joanne Williams**  
Assistant Operations Manager, Environmental Services, Analytical