



Not Reportable as per Chain of Custody
Works #: 1156

Project : PO#017018

SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - KOL 2H0
Phone: 705-652-2000 FAX: 705-652-6365

01-May-2014

OCWA-Trent Valley (Quinte Mohawk School)

Attn : James Taylor

Date Rec. : 29 April 2014

LR Report: CA17304-APR14

Box 20157, 131 St. Paul St.
Belleville, ON
K8N 5V1,

Copy: #1

Phone: 613-962-5454
Fax:pdf-ID Plant

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Temperature Time Upon Receipt °C | Total Chlorine mg/L | Free Chlorine mg/L | Total Coliform cfu/100mL | E. Coli Heterotrophic cfu/100mL | Plate Count (HPC) cfu/1mL |
|---|--|---------------------------|--------------------------|--------------------------------|------------------------------------|---------------------------------|
| 1: Analysis Start Date | --- | --- | --- | 29-Apr-14 | 29-Apr-14 | 29-Apr-14 |
| 2: Analysis Start Time | --- | --- | --- | 14:10 | 14:10 | 13:35 |
| 3: Analysis Approval Date | -- | -- | -- | 30-Apr-14 | 30-Apr-14 | 01-May-14 |
| 4: Analysis Approval Time | -- | -- | -- | 12:49 | 12:49 | 11:59 |
| 5: MAC | -- | -- | -- | 0 | 0 | --- |
| 6: 26F9D RW RW-QMS: Raw Water 26F9D RW | 28-Apr-14 08:05 | 13.0 | --- | 0 | 0 | 2 |
| 7: 6712 NR DW DW1-QMS Daycare 6712 NR/DW | 28-Apr-14 08:20 | 13.0 | 1.51 | 1.34 | 0 | 0 |
| 8: 6711 NR/DW DW3-QMS: Kitchen Tap 6711 NR/DW | 28-Apr-14 08:15 | 13.0 | 1.09 | 1.09 | 0 | 2 |

Total and/or Free Residual Chlorine was not analyzed by SGS Environmental Services.



Carrie Greenlaw
Project Specialist
Environmental Services, Analytical