



Not Reportable as per Chain of Custody
Works #: 1156

Project : PO#017018

SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - KOL 2H0
Phone: 705-652-2000 FAX: 705-652-6365

26-June-2014

OCWA-Trent Valley (Quinte Mohawk School)

Attn : James Taylor

Date Rec. : 24 June 2014
LR Report: CA17473-JUN14

Box 20157, 131 St. Paul St.
Belleville, ON
K8N 5V1,

Copy: #1

Phone: 613-962-5454
Fax:pdf-ID Plant

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature Upon Receipt °C | Total Chlorine mg/L | Free Chlorine mg/L | Total Coliform cfu/100mL | E. Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|--|--------------------|-----------------------------|---------------------|--------------------|--------------------------|-------------------|---|
| 1: Analysis Start Date | | --- | --- | --- | 24-Jun-14 | 24-Jun-14 | 24-Jun-14 |
| 2: Analysis Start Time | | --- | --- | --- | 11:50 | 11:50 | 11:15 |
| 3: Analysis Approval Date | | -- | --- | -- | 25-Jun-14 | 25-Jun-14 | 26-Jun-14 |
| 4: Analysis Approval Time | | -- | --- | -- | 17:35 | 17:35 | 11:36 |
| 5: MAC | | -- | --- | -- | 0 | 0 | --- |
| 6: 26F9D RW RW-QMS: Raw Water 26F9D RW | 23-Jun-14 08:30 | 16.0 | --- | --- | 1 | 0 | 4 |
| 7: 6712 NR DW DW1-QMS Daycare 6712 NR/DW | 23-Jun-14 08:20 | 16.0 | 1.52 | 1.30 | 0 | 0 | 3 |
| 8: 13480 NR/DW DW3-Girls Washroom Fountain 13480 NR/DW | 23-Jun-14 08:10 | 16.0 | 1.40 | 1.15 | 0 | 0 | 2 |

Total and/or Free Residual Chlorine was not analyzed by SGS Environmental Services.


 Carrie Greenlaw
 Project Specialist
 Environmental Services, Analytical