



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Project : PO#017018

January-07-13

OCWA-Trent Valley (Quinte Mohawk School)

Attn : Steve Arnold

Date Rec. : 03 January 2013
LR Report: CA17511-JAN13

Box 20157, 131 St. Paul St.
Belleville, ON
K8N 5V1,

Copy: #1

Phone: 613-962-5454
Fax:pdf-ID Plant

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Free Chlorine mg/L	Total Coliform cfu/100mL	E. Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	03-Jan-13	03-Jan-13	03-Jan-13
2: Analysis Start Time		---	---	15:15	15:15	14:40
3: Analysis Approval Date		---	---	04-Jan-13	04-Jan-13	07-Jan-13
4: Analysis Approval Time		---	---	15:52	15:52	09:35
5: MAC		---	---	0	0	---
6: 26F9D RW QMS: Raw water tap	02-Jan-13 10:04	1.0	---	0	0	0
7: 1ec6c NR/DW QMS: Staff Room Tap	02-Jan-13 10:31	1.0	1.46	0	0	0
8: 6712 NR/DW QMS: Daycare	02-Jan-13 10:42	1.0	1.41	0	0	0

Total and/or Free Residual Chlorine was not analyzed by SGS Environmental Services.

Carrie Greenlaw
Project Specialist
Environmental Services, Analytical