



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - KOL 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 1156
Project : PO#017018

10-October-2013

OCWA-Trent Valley (Quinte Mohawk School)

Attn : James Taylor

Date Rec. : 08 October 2013
LR Report: CA17580-OCT13

Box 20157, 131 St. Paul St.
Belleville, ON
K8N 5V1,

Copy: #1

Phone: 613-962-5454
Fax:pdf-ID Plant

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temp Upon Receipt °C	ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	HPC cfu/1mL
1: Analysis Start Date		---	---	08-Oct-13	08-Oct-13	08-Oct-13
2: Analysis Start Time		---	---	16:25	16:25	15:50
3: Analysis Approval Date		--	--	10-Oct-13	10-Oct-13	10-Oct-13
4: Analysis Approval Time		--	--	16:03	16:03	16:03
5: MAC		--	--	0	0	---
6: 26F9D RW RW-QMS: Raw Water	07-Oct-13 10:43	14.0	---	0	0	17
7: 6712 NR DW DW1-QMS Daycare	07-Oct-13 11:37	14.0	1.02	0	0	0
8: 1EC6A NR DW DW2-QMS Staff Room Tap	07-Oct-13 11:22	14.0	0.98	0	0	0

Total and/or Free Residual Chlorine was not analyzed by SGS Environmental Services.
NR - Not reportable under applicable Provincial drinking water regulations as per client.

Kimberley Didsbury
Project Specialist
Environmental Services, Analytical