



**SGS Canada Inc.**  
P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - KOL 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

**Not Reportable as per Chain of Custody Works #: 1156**

**Project : PO#017018**

23-October-2014

**OCWA-Trent Valley (Quinte Mohawk School)**

Attn : James Taylor

**Date Rec. : 21 October 2014**

**LR Report: CA17605-OCT14**

Box 20157, 131 St. Paul St.  
Belleville, ON  
K8N 5V1,

**Copy: #1**

Phone: 613-962-5454  
Fax:pdf-ID Plant

## CERTIFICATE OF ANALYSIS

### Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Total Chlorine mg/L	Free Chlorine mg/L	Total Coliform cfu/100mL	E. Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	---	21-Oct-14	21-Oct-14	21-Oct-14
2: Analysis Start Time		---	---	---	17:50	17:50	17:25
3: Analysis Approval Date		--	---	--	23-Oct-14	23-Oct-14	23-Oct-14
4: Analysis Approval Time		--	---	--	11:22	11:22	15:15
5: MAC		--	---	--	0	0	---
6: 26F9D RW RW-QMS: Raw Water 26F9D RW	20-Oct-14 08:35	15.0	---	---	0	0	4
7: 6712 NR DW DW1-QMS Daycare 6712 NR/DW	20-Oct-14 08:25	15.0	1.57	1.30	0	0	0
8: 6711 NR DW DW3-Kitchen Sink 6711 NR/DW	20-Oct-14 08:15	15.0	1.45	1.24	0	0	0

Total and/or Free Residual Chlorine was not analyzed by SGS Environmental Services.

#### Method Descriptions

	Parameter	Unit	Description	SGS Method Code
1	E. Coli	cfu/100mL	E.Coli by membrane filtration on DC media	ME-CA-[ENV]MIC-LAK-AN-001
2	Heterotrophic Plate Count (HPC)	cfu/1mL	Heterotrophic Plate Count by membrane filtration	ME-CA-[ENV]MIC-LAK-AN-005
3	Total Coliform	cfu/100mL	Total Coliform by membrane filtration using DC media	ME-CA-[ENV]MIC-LAK-AN-001

  
**Carrie Greenlaw**  
Project Specialist  
Environmental Services, Analytical