

SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - KOL 2H0
Phone: 705-652-2000 FAX: 705-652-6365

08-November-2013

OCWA-Trent Valley (Quinte Mohawk School)

Attn : James Taylor

Date Rec. : 05 November 2013
LR Report: CA17683-NOV13

Box 20157, 131 St. Paul St.
Belleville, ON
K8N 5V1,

Copy: #1

Phone: 613-962-5454
Fax:pdf-ID Plant

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Free Chlorine mg/L	Total Coliform cfu/100mL	E. Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	05-Nov-13	05-Nov-13	05-Nov-13
2: Analysis Start Time		---	---	17:05	17:05	16:35
3: Analysis Approval Date		--	--	07-Nov-13	07-Nov-13	07-Nov-13
4: Analysis Approval Time		--	--	14:21	14:21	16:59
5: MAC		--	--	0	0	---
6: 26F9D RW RW-QMS: Raw Water 26F9D NR	04-Nov-13 09:07	13.0	---	0	0	8
7: 6712 NR DW DW1-QMS Daycare 6712 NR	04-Nov-13 09:33	13.0	1.24	0	0	3
8: 1EC6A NR DW DW2-QMS Staff Room Tap 1EC6A NR	04-Nov-13 09:40	13.0	1.08	0	0	0

Total and/or Free Residual Chlorine was not analyzed by SGS Environmental Services.



Carrie Greenlaw
Project Specialist
Environmental Services, Analytical