



**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - K0L 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

**Project :** PO#017018

March-21-13

**OCWA-Trent Valley (Quinte Mohawk School)**

Attn : James Taylor

**Date Rec. :** 19 March 2013  
**LR Report:** CA17737-MAR13

Box 20157, 131 St. Paul St.  
Belleville, ON  
K8N 5V1,

**Copy:** #1

Phone: 613-962-5454  
Fax:pdf-ID Plant

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Free Chlorine mg/L	Total Coliform cfu/100mL	E. Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	19-Mar-13	19-Mar-13	19-Mar-13
2: Analysis Start Time		---	---	13:50	13:50	13:15
3: Analysis Approval Date		--	--	20-Mar-13	20-Mar-13	21-Mar-13
4: Analysis Approval Time		--	--	15:03	15:03	12:42
5: MAC		--	--	0	0	---
6: 6712 NR/DW QMS Daycare	18-Mar-13 11:13	8.0	1.40	0	0	0
7: 1EC6A NR/DW QMS Staff Room Tap	18-Mar-13 11:21	8.0	1.33	0	0	0

Total and/or Free Residual Chlorine was not analyzed by SGS Environmental Services.



Carrie Greenlaw  
Project Specialist  
Environmental Services, Analytical