



**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - K0L 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

**Works #: 1156**

**Project : PO#017018**

14-November-2014

**OCWA-Trent Valley (Quinte Mohawk School)**

Attn : James Taylor

**Date Rec. : 11 November 2014**

**LR Report: CA17797-NOV14**

Box 20157, 131 St. Paul St.  
Belleville, ON  
K8N 5V1,

**Copy: #1**

Phone: 613-962-5454  
Fax:pdf-ID Plant

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temp Upon Receipt °C	ResCl Total mg/L	ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	HPC cfu/1mL
1: Analysis Start Date		---	---	---	11-Nov-14	11-Nov-14	11-Nov-14
2: Analysis Start Time		---	---	---	14:20	14:20	13:35
3: Analysis Approval Date		--	---	--	13-Nov-14	13-Nov-14	13-Nov-14
4: Analysis Approval Time		--	---	--	13:26	13:26	13:26
5: MAC		--	---	--	0	0	---
6: 26F9D RW RW-QMS: Raw Water 26F9D RW	10-Nov-14 08:40	13.0	---	---	0	0	16
7: 6712 NR DW DW1-QMS Daycare 6712 NR/DW	10-Nov-14 08:35	13.0	1.60	1.35	0	0	1
8: 1F432 NR/DW DW3-QMS: Front Entrance Fountain 1F432 NR/DW	10-Nov-14 08:25	13.0	1.24	0.92	0	0	121

Total and/or Free Residual Chlorine was not analyzed by SGS Environmental Services.  
NR - Not reportable under applicable Provincial drinking water regulations as per client.

### Method Descriptions

	Parameter	Description	SGS Method Code
1	E. Coli	E.Coli by membrane filtration on DC media	ME-CA-[ENV]MIC-LAK-AN-001
2	Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count by membrane filtration	ME-CA-[ENV]MIC-LAK-AN-005
3	Total Coliform	Total Coliform by membrane filtration using DC media	ME-CA-[ENV]MIC-LAK-AN-001

Kimberley Didsbury  
Project Specialist  
Environmental Services, Analytical