



**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - K0L 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

**Project :** PO#017018

March-28-13

**OCWA-Trent Valley (Quinte Mohawk School)**

Attn : James Taylor

**Date Rec. :** 26 March 2013  
**LR Report:** CA18095-MAR13

Box 20157, 131 St. Paul St.  
Belleville, ON  
K8N 5V1,

**Copy:** #1

Phone: 613-962-5454  
Fax:pdf-ID Plant

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Free Chlorine mg/L	Total Coliform cfu/100mL	E. Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	26-Mar-13	26-Mar-13	26-Mar-13
2: Analysis Start Time		---	---	13:10	13:10	12:35
3: Analysis Approval Date		---	---	27-Mar-13	27-Mar-13	28-Mar-13
4: Analysis Approval Time		---	---	17:18	17:18	11:23
5: MAC		---	---	0	0	---
6: 6712 NR/DW QMS Daycare	25-Mar-13 09:52	10.0	1.39	0	0	0
7: 13480 NR/DW QMS:Fountain Water Girl's Bathroom	25-Mar-13 10:01	10.0	1.34	0	0	1

Total and/or Free Residual Chlorine was not analyzed by SGS Environmental Services.



*Carrie Greenlaw*  
Carrie Greenlaw  
Project Specialist  
Environmental Services, Analytical