



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - KOL 2H0
Phone: 705-652-2000 FAX: 705-652-6365

OCWA-Trent Valley (Quinte Mohawk School)

Attn : James Taylor

Box 20157, 131 St. Paul St.
Belleville, ON
K8N 5V1,

Phone: 613-962-5454
Fax:pdf-ID Plant

Works #: 1156
Project : PO#017018

01-August-2014

Date Rec. : 30 July 2014
LR Report: CA18206-JUL14

Copy: #1

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temp Upon Receipt °C	ResCl Total mg/L	ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	HPC cfu/1mL
1: Analysis Start Date		---	---	---	30-Jul-14	30-Jul-14	30-Jul-14
2: Analysis Start Time		---	---	---	12:50	12:50	12:15
3: Analysis Approval Date		--	---	--	31-Jul-14	31-Jul-14	01-Aug-14
4: Analysis Approval Time		--	---	--	15:11	15:11	11:18
5: MAC		--	---	--	0	0	---
6: 26F9D RW RW-QMS: Raw Water 26F9D RW	29-Jul-14 08:20	19.0	---	---	0	0	1
7: 6712 NR DW DW1-QMS Daycare 6712 NR/DW	29-Jul-14 08:15	19.0	1.82	1.53	0	0	5
8: 13480 NR/DW DW3-QMS: Fountain Water Girls Bathroom 13480 NR/DW	29-Jul-14 08:05	19.0	1.56	1.40	0	0	0

Total and/or Free Residual Chlorine was not analyzed by SGS Environmental Services.
NR - Not reportable under applicable Provincial drinking water regulations as per client.

Kimberley Didsbury
Project Specialist
Environmental Services, Analytical