



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Project : PO#017018

January-24-13

OCWA-Trent Valley (Quinte Mohawk School)

Attn : Steve Arnold

Date Rec. : 22 January 2013
LR Report: CA18140-JAN13

Box 20157, 131 St. Paul St.
Belleville, ON
K8N 5V1,

Copy: #1

Phone: 613-962-5454
Fax:pdf-ID Plant

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Free Chlorine mg/L	Total Coliform cfu/100mL	E. Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	22-Jan-13	22-Jan-13	22-Jan-13
2: Analysis Start Time		---	---	13:25	13:25	13:00
3: Analysis Approval Date		--	--	24-Jan-13	24-Jan-13	24-Jan-13
4: Analysis Approval Time		--	--	09:06	09:06	11:14
5: MAC		--	--	0	0	---
6: 6712 NR/DW QMS Daycare	21-Jan-13 11:05	5.0	1.17	0	0	1
7: 1EC6A NR/DW QMS Staff Room Tap	21-Jan-13 11:13	5.0	1.16	0	0	2

Total and/or Free Residual Chlorine was not analyzed by SGS Environmental Services.



Carrie Greenlaw
Project Specialist
Environmental Services, Analytical