

Trent Valley Hub  
 131 St. Paul Street  
 PO Box 20157  
 Belleville, Ontario  
 K8N 5V1  
 Tel: (613) 962-5454  
 Fax: (613) 962-1966

January 7, 2013

Mr. Todd Kring  
 Director of Community Infrastructure  
 Mohawks of the Bay of Quinte  
 Tyendinaga Mohawk Territory  
 RR #1, 13 Old York Road  
 Deseronto, Ontario  
 K0K 1X0

Dear Mr. Kring;


**RE: Quinte Mohawk School Bacteriological Sample Results**

On December 27th, 2012, the Ontario Clean Water Agency (OCWA) collected routine weekly bacteriological distribution water samples at the Quinte Mohawk School Drinking Water System (DWS) and on the 28th bacteriological raw and distribution water samples at the Quinte Mohawk School Drinking Water System (DWS) were collected after reservoir cleaning. The samples were analyzed for total coliform (TC), E. Coli (EC) and Heterotrophic plate count (HPC). The results of the sample analyses show that TC and EC are both 0 (i.e. non-detectable) and meet regulatory requirements. The HPC results for the Quinte Mohawk School DWS distribution samples also are 0 (i.e. non-detectable) and the raw had a count of 415 cfu/1mL. There is no maximum acceptable concentration specified for HPC. HPC gives an indication of overall water quality in drinking water systems and are not an indicator of water safety and should not be used as an indicator of potential adverse human health effects. The results are tabulated below and copies of the lab analysis reports are attached.

<b>Bacteriological Sample Results Summary – Sample Date: December 27 &amp; 28, 2012</b>						
Parameter	Quinte Mohawk School DWS		Quinte Mohawk School DWS			Ontario Drinking Water Standard
	Daycare	Water Fountain Outside Daycare	Daycare	Room 32	Raw	
Total Coliform – cfu/100mL	0	0	0	0	0	Non-Detectable
E. Coli – cfu/100mL	0	0	0	0	0	Non-Detectable
Heterotrophic Plate Count – cfu/1mL	0	0	0	0	415	None Specified

If you have any questions or concerns please contact me.

Sincerely,

  
 James Taylor  
 Special Projects Manager  
 Ontario Clean Water Agency

cc: Jamie Hennigar, Senior Operations Manager, OCWA  
 John C. Seguire, Operations Manager, OCWA  
 Wes Henneberry, Process & Compliance Technician, OCWA  
 Joanne Arnold, Regional Compliance Advisor, OCWA