



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Project : PO#017018

November-22-12

OCWA-Trent Valley (Quinte Mohawk School)

Attn : Steve Arnold

Date Rec. : 20 November 2012
LR Report: CA17647-NOV12

Box 20157, 131 St. Paul St.
Belleville, ON
K8N 5V1,

Copy: #1

Phone: 613-962-5454
Fax:pdf-ID Plant

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Temperature Time Upon Receipt °C	Free Chlorine mg/L	Total Coliform cfu/100mL	E. Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date	---	---	20-Nov-12	20-Nov-12	20-Nov-12
2: Analysis Start Time	---	---	15:00	15:00	14:30
3: Analysis Approval Date	---	---	21-Nov-12	21-Nov-12	22-Nov-12
4: Analysis Approval Time	---	---	15:37	15:37	14:34
5: MAC	---	---	--	--	--
6: 6712 NR/DW QMS Daycare	19-Nov-12 08:08	6.0	1.49	0	0
7: 1F432 NR/DW QMS Fountain Water Front Entrance	19-Nov-12 08:15	6.0	1.02	0	0

Total and/or Free Residual Chlorine was not analyzed by SGS Environmental Services.

Carrie Greenlaw
Project Specialist
Environmental Services, Analytical