



Not Reportable as per Chain of Custody

**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - K0L 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

**Project :** PO#017018

October-18-12

**OCWA-Trent Valley (Quinte Mohawk School)**

Attn : Steve Arnold

**Date Rec. :** 16 October 2012

**LR Report:** CA17726-OCT12

Box 20157, 131 St. Paul St.  
Belleville, ON  
K8N 5V1,

**Copy:** #1

Phone: 613-962-5454  
Fax:pdf-ID Plant

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Free Chlorine mg/L	E. Coli cfu/100mL	Total Coliform cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	16-Oct-12	16-Oct-12	16-Oct-12
2: Analysis Start Time		---	---	13:20	13:20	12:45
3: Analysis Approval Date		---	---	18-Oct-12	18-Oct-12	18-Oct-12
4: Analysis Approval Time		---	---	12:39	12:39	12:39
5: MAC		---	---	--	--	--
6: 6712 NR/DW QMS Daycare	15-Oct-12 09:25	12.0	1.20	0	0	0
7: 1F432 NR/DW QMS Fountain Water Front Entrance	15-Oct-12 09:31	12.0	0.74	0	0	0

Total and/or Free Residual Chlorine was not analyzed by SGS Environmental Services.

Carrie Greenlaw  
Project Specialist  
Environmental Services, Analytical