

Fire Department Water Tanker Shuttle Accreditation

Presented To: Tyendinaga Mohawk Territory

ACCREDITED FIRE STATIONS

F.S York Road (6)

Date Test Passed: October 9th 2019

Flow Achieved: 626 I.G.P.M. 2,850 LITERS/MIN.

Two (2) Hour Test Time



Signed: Elaine Rose
Elaine Rose
Partner

This Certificate Expires on: October 1st 2024